

South Jersey Water Test, LLC 4077 South Black Horse Pike Williamstown, NJ 08094 856-875-3506 Phone 856-875-3507 Fax

Children on the Green 50 South Park Place Morristown, NJ 07960 973-984-0094

www.sjwatertest.com NJ DEP Certified Lab # 08006

Sample Location:

Field Reagent Blank

Date Sampled: 04/18/21

Time Sampled: 08:40

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T105966					
Lead	22-APR-2021 15:35	<2.00	ug/L	2.0	15.5	SM3113B
Copper	22-APR-2021 15:14	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location:

Infant Room

Date Sampled: 04/18/21

Time Sampled: 08:42

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T105967					
Lead	22-APR-2021 15:42	<2.00	ug/L	2.0	15.5	SM3113B
Copper	22-APR-2021 15:15	0.412	mg/L	0.05	1.3	SM3111B

Sample Location:

Kitchen

Date Sampled: 04/18/21

Time Sampled: 08:43

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T105968					
Lead	22-APR-2021 15:49	<2.00	ug/L	2.0	15.5	SM3113B
Copper	22-APR-2021 15:15	0.192	mg/L	0.05	1.3	SM3111B

Sample Location:

Toddler Bathroom

Date Sampled: 04/18/21

Time Sampled: 08:44

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T105969					
Lead	22-APR-2021 16:09	<2.00	ug/L	2.0	15.5	SM3113B
Copper	22-APR-2021 15:16	0.226	mg/L	0.05	1.3	SM3111B

Sample Location:

Water Cooler .

Date Sampled: 04/18/21

Time Sampled: 08:45

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T105970					
Lead	22-APR-2021 16:15	<2.00	ug/L	2.0	15.5	SM3113B
Copper	22-APR-2021 15:16	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location:

Preschool

Date Sampled: 04/18/21

Time Sampled: 08:52

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T105971	-				
Lead	22-APR-2021 16:22	9.98	ug/L	2.0	15.5	SM3113B
Copper	22-APR-2021 15:13	0.302	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

04/23/2021

Date



South Jersey Water Test, LLC 4077 South Black Horse Pike Williamstown, NJ 08094 856-875-3506 Phone 856-875-3507 Fax

Children on the Green 50 South Park Place Morristown, NJ 07960 973-984-0094

www.sjwatertest.com

Sample Location:

Early Preschool

Date Sampled: 04/18/21

Time Sampled: 08:54

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T105972					
Lead	22-APR-2021 16:41	5.26	ug/L	2.0	15.5	SM3113B
Copper	22-APR-2021 15:18	0.160	mg/L	0.05	1.3	SM3111B

Sample Location:

Girls Bathroom - Right Sink

Date Sampled: 04/18/21

Time Sampled: 08:55

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T105973					
Lead	22-APR-2021 16:48	7.63	ug/L	2.0	15.5	SM3113B
Copper	22-APR-2021 15:18	0.208	mg/L	0.05	1.3	SM3111B

Sample Location:

Water Fountain

Date Sampled: 04/18/21

Time Sampled: 08:55

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T105974					
Lead	22-APR-2021 16:54	37.75	ug/L	2.0	15.5	SM3113B
Copper	22-APR-2021 15:18	0.284	mg/L	0.05	1.3	SM3111B

Sample Location:

Boys Bathroom - Right Sink

Date Sampled: 04/18/21

Time Sampled: 08:56

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T105975					
Lead	22-APR-2021 17:01	2.26	ug/L	2.0	15.5	SM3113B
Copper	22-APR-2021 15:19	0.230	mg/L	0.05	1.3	SM3111B

Sample Location:

Pre-K

Date Sampled: 04/18/21

Time Sampled: 08:57

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T105976					
Lead	22-APR-2021 17:07	6.50	ug/L	2.0	15.5	SM3113B
Copper	22-APR-2021 15:19	0.147	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

04/23/2021

Date

CHAIN OF CUSTODY RECORD



South Jersey Water Test, LLC 4077 South Black Horse Pike Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.sjwatertest.com

NJ DEP Certification #08006

Customer:		Children on the Green	
Contact		Andrew Cattano	
Address:		50 South Park Place	
		Morristown, NJ 07960	
Phone:	973-984-0094	Fax:	
Office:			

Lab ID#	Sample Location	Colle Date	ection Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
T105966	Field Reagent Blank	4-18-21	840 mm	Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
T105967	Incant Room	4/18/21	842 AM	Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
T105968	Kidchen	4/18/4	893	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
7105969	Toddle-bathroun	7/18/21	844	Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
T105970	water cooler	4/18/4	245	Х		D	1 x 250	HNO3*	First Draw Lead and Copper	Filter
T105971	Preschool	4/18/23	825	Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
T105972	Eury Preschool	4118/4	859	Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
T105973	CADA	4/18/4	855	Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
	1	-		Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
		_		Х		D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: DIDRINKING WATER AVAQUEOUS SISOIL SLISLUDGE GWIGROUND WATER SWISURFACE WATER WWIWASTE WATER

Turnaround Time Report Format			Comments/Special Instructions	Cooler Temp	
SJWT Standard is 10-20 work days	Standard NJ DEP Reduce		LINO2	Properly Preserv	°C
Rush turnaround available upon request and lab approval	NJ DEP Full De Electronic Data PWTA Format		* HNO3 preserved upon receipt at laboratory	(Yes)	No
Sampled by: (Print) Andrew T Contdon					
Sampled by/Relinquished by: (Signature)	Date 8/AIU		ceived by:	Date 4 20 21	Time 1045
Relinquished by: (Signature)	Date	1000	ignature)	Date	Time
Relinquished by: (Signature)	Date		ceived by: ignature)	Date	Time

CHAIN OF CUSTODY RECORD

1.0

South Jersey Water Test, LLC

4077 South Black Horse Pike Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.sjwatertest.com

NJ DEP Certification #08006

			COLUMN TO THE OWNER OF THE OWNER OWN
Customer:		Children on the Green	
Contact		Andrew Cattano	
Address:		50 South Park Place	
		Morristown, NJ 07960	
Phone:	973-984-0094	Fax:	
Office:			

Lab ID#	Sample Location	Collect Date	ction Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
TO5979	Water fortin	11/8/21	855	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
±105975	Boys both our Right S.1 K	4/18/21	856	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
T105976	D' V	4/14/4	857	Х		D	1 x 250	HNO3*	First Draw Lead and Copper]
				Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
				Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
				Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
				Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
				Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: D\DRINKING WATER AVAQUEOUS S\SOIL SL\SLUDGE GW\GROUND WATER SW\SURFACE WATER WW\WASTE WATER

Turnaround Time Report Format Standard			Comments/Special Instructions	Cooler Tem	р
SJWT Standard is 10-20 work days	NJ DEP Reduce	ed Deliverables			°C
Rush turnaround available upon request	NJ DEP Full De		* HNO3 preserved upon receipt at laboratory	Properly Prese	erved
and lab approval Electronic Data Deliverables PWTA Format			Yes	No	
Sampled by: (Print) Andrew To Codd on					
Sampled by/Relinquished by: (Signature)	Date 8/19/1		eceived by: ignature)	Date 4 20 21	Time 1045
Relinquished by: (Signature)	Date		eceived by: ignature)	Date	Time
Relinquished by: (Signature)	Date	Section 2015	eceived by: ignature)	Date	Time



South Jersey Water Test, LLC 4077 South Black Horse Pike Williamstown, NJ 08094 856-875-3506 Phone 856-875-3507 Fax

Children on the Green 50 South Park Place Morristown, NJ 07960 973-984-0094

www.sjwatertest.com NJ DEP Certified Lab # 08006

Sample Location:

Field Reagent Blank

Date Sampled: 05/20/21

Time Sampled: 10:40

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T107171					
Lead	24-MAY-2021 16:22	<2.00	ug/L	2.0	15.5	SM3113B
Copper	24-MAY-2021 13:54	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location:

Water Fountain

Date Sampled: 05/20/21

Time Sampled: 10:45

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T107172					
Lead	24-MAY-2021 16:29	5.13	ug/L	2.0	15.5	SM3113B
Copper	24-MAY-2021 13:54	0.117	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

07/08/2021

D	- 6	
Page	 Oţ	

CHAIN OF CUSTODY RECORD



South Jersey Water Test, LLC

4077 South Black Horse Pike Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.siwatertest.com
NJ DEP Certification #08006

	Of I	
Customer:	Children on the Green	
Contact	Andrew Cattano	
Address:	50 South Park Place	
	Morristown, NJ 07960	
Phone:	Fax:	
Office:		

Lab ID#	Sample Location	Collection Date Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	Field Reagent Blank		Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
T107172	Water Fountain	5/20/10:45	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
			Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
			Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
			Х		D	1 x 250	ниоз*	First Draw Lead and Copper	
			Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
			Х		D	1 x 250	HNO3*	First Draw Lead and Copper	
			X		D	1 x 250	HNO3*	First Draw Lead and Copper	
			X		D	1 x 250	HNO3*	First Draw Lead and Copper	
			Х		D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: D\DRINKING WATER AVAQUEOUS S\SOIL SL\SLUDGE GW\GROUND WATER SW\SURFACE WATER WW\WASTE WATER

Turnaround Time	Report Fo	ormat	Comments/Special Instructions	Cooler Temp	
Standard SJWT Standard is 10-20 work days NJ DEP Reduced Deliverables Rush turnaround available upon request NJ DEP Full Deliverables			* HNO3 preserved upon receipt at laboratory	Properly Preserved	°C
and lab approval	Electronic Data Deliverables PWTA Format			Yes	No
Sampled by: (Print) Linder T. (attano					
Sampled by/Relinquished by: (Signature)	Date \$ונסחן		eceived by: signature)	Date 5/21/21	Time 1145
Relinquished by: (Signature)	Date		eceived by: ignature)	Date	Time
Relinquished by: (Signature)	Date		eceived by: Signature)	Date	Time



April 2021

Dear Parents,

As part of our state license renewal process (every 3 years), we are required to test water samples for lead and copper. Samples are collected from water outlets that a child or staff member have access to. Upon completing this year's sampling it was found that one drinking fountain in the 2nd floor hallway tested above the 15.5 micrograms/liter limit for lead.

While the children do have access to this fountain, *they do not use it*. It has been our standard practice for well over a year that the children only drink bottled water or water from our water cooler, which tested well below the limit.

This water fountain has been marked **Do Not Use** and I've spoken to all teachers about this issue. When this fountain was tested 3 years ago, during our last renewal process, it tested well below the limits. A possible reason for the higher levels this time could be lack of use. We will be retesting it ASAP and will provide you the results. While we await the results of the re-testing, we will use only bottled water for drinking and food preparation.

Attached are the full results of this year's testing.

Please let us know if any questions.

Thank you.