



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Children on the Green
50 South Park Place
Morristown, NJ 07960
973-984-0094

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Field Reagent Blank Date Sampled: 05/08/24 Time Sampled: 06:35

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138143					
Lead	14-MAY-2024 13:15	<2.00	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:30	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Water Cooler Date Sampled: 05/08/24 Time Sampled: 06:40

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138144					
Lead	14-MAY-2024 13:21	<2.00	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:29	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Toddler Bathroom Date Sampled: 05/08/24 Time Sampled: 06:40

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138145					
Lead	14-MAY-2024 13:28	<2.00	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:31	0.313	mg/L	0.05	1.3	SM3111B

Sample Location: Infant Sink Date Sampled: 05/08/24 Time Sampled: 06:41

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138146					
Lead	14-MAY-2024 13:34	<2.00	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:31	0.474	mg/L	0.05	1.3	SM3111B

Sample Location: Boy Room 2 Right Date Sampled: 05/08/24 Time Sampled: 06:45

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138147					
Lead	14-MAY-2024 13:41	<2.00	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:32	0.278	mg/L	0.05	1.3	SM3111B

Sample Location: Water Fountain 2 Date Sampled: 05/08/24 Time Sampled: 06:46

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138148					
Lead	14-MAY-2024 13:47	38.47	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:32	0.324	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

05/15/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Children on the Green
50 South Park Place
Morristown, NJ 07960
973-984-0094

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Girls Room 2 Left

Date Sampled: 05/08/24

Time Sampled: 06:47

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138149					
Lead	14-MAY-2024 14:07	<2.00	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:33	0.269	mg/L	0.05	1.3	SM3111B

Sample Location: Before/After Care

Date Sampled: 05/08/24

Time Sampled: 06:50

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138150					
Lead	14-MAY-2024 14:14	<2.00	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:34	0.281	mg/L	0.05	1.3	SM3111B

Sample Location: Early Preschool

Date Sampled: 05/08/24

Time Sampled: 06:51

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138151					
Lead	14-MAY-2024 14:21	<2.00	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:34	0.239	mg/L	0.05	1.3	SM3111B

Sample Location: Water Fountain 1

Date Sampled: 05/08/24

Time Sampled: 06:54

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138152					
Lead	14-MAY-2024 14:27	4.63	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:35	0.364	mg/L	0.05	1.3	SM3111B

Sample Location: Girls Room 1 Left

Date Sampled: 05/08/24

Time Sampled: 06:55

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138153					
Lead	14-MAY-2024 14:34	<2.00	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:35	0.255	mg/L	0.05	1.3	SM3111B

Sample Location: Janitors Closet

Date Sampled: 05/08/24

Time Sampled: 06:55

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138154					
Lead	14-MAY-2024 14:40	<2.00	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:35	0.100	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

05/15/2024

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Children on the Green
50 South Park Place
Morristown, NJ 07960
973-984-0094

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Boys Room 1 Right

Date Sampled: 05/08/24

Time Sampled: 06:56

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138155					
Lead	14-MAY-2024 14:47	<2.00	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:36	0.375	mg/L	0.05	1.3	SM3111B

Sample Location: Pre K 3

Date Sampled: 05/08/24

Time Sampled: 06:57

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W138156					
Lead	14-MAY-2024 14:54	4.93	ug/L	2.0	15.5	SM3113B
Copper	13-MAY-2024 13:36	0.215	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

05/15/2024

Date

CHAIN OF CUSTODY RECORD



South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer:	Children on the Green
Contact	Andrew Cattano
Address:	50 South Park Place Morristown, NJ 07960
Phone:	Fax:
Office:	

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W138143	Field Reagent Blank	5/8	6:35	X		D	1 x 250	HNO3*	First Draw Lead and Copper	water filter
W138144	Water cooler	5/8/14	6:40	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138145	Toddler Bathroom	5/8	6:40	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138146	Infant Sink	5/8	6:41	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138147	Boy Room 2 Right	5/8	6:45	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138148	Water fountain 2	5/8	6:46	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138149	Girls Room 2 Left	5/8	6:47	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138150	Before/Afterschool	5/8	6:50	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138151	Early Preschool	5/8	6:51	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138152	Water fountain 1	5/8	6:54	X		D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: D\DRINKING WATER A\AQUEOUS S\SOIL SL\SLUDGE GW\GROUND WATER SW\SURFACE WATER WWWASTE WATER

Turnaround Time ___ SJWT Standard is 10-20 work days ___ Rush turnaround available upon request and lab approval _____	Report Format ___ Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWT A Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
			Properly Preserved
			Yes No

Sampled by: (Print) Andrew Cattano					
Sampled by/Relinquished by: (Signature) [Signature]	Date 5/8	Time 10:47	Received by: (Signature) [Signature]	Date 5/9/2014	Time 11:30
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time

CHAIN OF CUSTODY RECORD



South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer:	Children on the Green
Contact	Andrew Cattano
Address:	50 South Park Place Morristown, NJ 07960
Phone:	Fax:
Office:	

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
W138153	Girls room 1 left	5/8/14	655	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138154	Jan. Room Closed	5/8/14	655	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138155	Boys Room 1 Right	5/8/14	656	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
W138156	Pre K-3	5/8/14	657	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: D\DRINKING WATER A\AQUEOUS S\SOIL SL\SLUDGE GW\GROUND WATER SW\SURFACE WATER WW\WASTE WATER

Turnaround Time ___ SJWT Standard is 10-20 work days ___ Rush turnaround available upon request and lab approval _____	Report Format ___ Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions _____ _____ * HNO3 preserved upon receipt at laboratory	Cooler Temp _____ °C	
			Properly Preserved	
			Yes	No

Sampled by:
 (Print) Andrew Cattano

Sampled by/Relinquished by: (Signature) <i>[Signature]</i>	Date 5/8	Time 10:30 AM	Received by: (Signature) <i>[Signature]</i>	Date 5/9/14	Time 11:30
Relinquished by: (Signature) _____	Date _____	Time _____	Received by: (Signature) _____	Date _____	Time _____
Relinquished by: (Signature) _____	Date _____	Time _____	Received by: (Signature) _____	Date _____	Time _____



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Children on the Green
50 South Park Place
Morristown, NJ 07960
973-984-0094

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Field Reagent

Date Sampled: 07/02/24

Time Sampled: 06:55

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W139952					
Lead	3-JUL-2024 11:55	<2.00	ug/L	2.0	15.5	SM3113B
Copper	3-JUL-2024 13:22	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Water Fountain

Date Sampled: 07/02/24

Time Sampled: 07:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W139953					
Lead	3-JUL-2024 12:02	<2.00	ug/L	2.0	15.5	SM3113B
Copper	3-JUL-2024 13:23	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

07/05/2024

Date

CHAIN OF CUSTODY RECORD



South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.siwatertest.com
 NJ DEP Certification #08006

Customer:	Children on The Green
Contact	Andrew Cattano
Address:	50 South Park Place Morristown, NJ 07960
Phone:	Fax:
Office:	

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
WJ39952	Field Reagent Blank	7/11/24	6:55	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
WJ39953	Water Fountain	7/11	7AM	X		D	1 x 250	HNO3*	First Draw Lead and Copper	Retest Retest
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: D\DRINKING WATER A\AQUEOUS S\SOIL SL\SLUDGE GW\GROUND WATER SW\SURFACE WATER WW\WASTE WATER

Turnaround Time ____ SJWT Standard is 10-20 work days ____ Rush turnaround available upon request and lab approval _____	Report Format ____ Standard ____ NJ DEP Reduced Deliverables ____ NJ DEP Full Deliverables ____ Electronic Data Deliverables ____ PWTA Format	Comments/Special Instructions	Cooler Temp	
		* HNO3 preserved upon receipt at laboratory	°C	
			Properly Preserved	
			Yes	No

Sampled by: (Print) Andrew Cattano						
Sampled by/Relinquished by: (Signature) <i>CA</i>		Date	Time	Received by:	Date	Time
		7/11/24	1800	<i>[Signature]</i>	7/12/24	11:30
Relinquished by: (Signature)		Date	Time	Received by:	Date	Time
Relinquished by: (Signature)		Date	Time	Received by:	Date	Time



May 2024

Dear Parents,

As part of our state license renewal process (every 3 years), we are required to test water samples for lead and copper. Samples are collected from water outlets that a child or staff member have access to. Upon completing this year's sampling it was found that one drinking fountain on the 2nd floor hallway tested above the 15.5 micrograms/liter limit for lead.

While the children do have access to this fountain, *they do not use it*. It has been our standard practice for several years that the children only drink water from our water cooler, which tested below the limit.

This water fountain has been marked **Do Not Use** and we have spoken to all teachers about this issue.

A possible reason for the higher levels could be lack of use. We will be retesting it ASAP and will provide you the results.

Attached are the full results of this year's testing.

Please let us know if any questions.

Thank you.